



CUSTOMER:  
MODEL:  
DATE:

SPECIFICATIONS

MEDIA:  
MEDIA VOLUME:  
ESTIMATED MEDIA LIFE:  
MEDIA TANK SIZE DIA. X HEIGHT:  
MAX. TEMPERATURE: 100 DEG. F.  
PRESSURE RANGE: 30-100 PSI  
SERVICE FLOW RATE:  
BACKWASH FLOW RATE:  
FACTORY TIMER SETTINGS  
BACKWASH:  
RAPID RINSE:  
FREQUENCY:  
REGENERATION TIME: 2:00 A.M.

INSTALLATION & START-UP

FOLLOW THESE INSTRUCTIONS FOR SYSTEMS SENT WITH MEDIA LOADED. FOR UNITS SHIPPED WITH MEDIA SEPARATE FOLLOW INSTRUCTIONS TAPED TO MEDIA CARTON

1. TURN OFF WATER AND LEAVE VALVE UNPLUGGED
2. INSTALL ON COLD WATER LINE ONLY
3. FOLLOW THE INSTRUCTIONS INCLUDED IN THE LINE CONNECTION FITTINGS
4. CONNECT IN/OUT LINES PER LOCAL CODES
5. CONNECT DRAIN LINE TO DRAIN THAT CAN HANDLE THE SPECIFIED FLOW. TO AVOID FUTURE PROBLEMS SIZE PIPE TO DRAIN FITTING AND USE RIGID PIPE
6. PLUG IN TIMER, PUSH REGEN BUTTON AND WHEN VALVE IS IN THE BACKWASH POSITION, UNPLUG THE VALVE
7. CLOSE THE OUTLET BY-PASS VALVE AND VERY SLOWLY OPEN THE WATER SUPPLY. RUN UNTIL NO MORE AIR GOES TO DRAIN.
8. IF A CARBON FILTER LET UNIT SET FOR 1 HOUR. IF NOT CARBON GO IMMEDIATELY TO 9.
9. PLUG THE TIMER IN. THE BACKWASH CYCLE WILL FINISH AND RAPID RINSE WILL TAKE PLACE
10. WHEN FLOW STOPS PUSH THE REGEN BUTTON AND HOLD FOR 5 SECONDS. UNIT WILL GO THROUGH A BACKWASH AND RAPID RINSE CYCLE AUTOMATICALLY. REPEAT UNTIL WATER TO DRAIN RUNS CLEAR AT END OF CYCLES
11. OPEN THE BY-PASS OUTLET VALVE AND SET THE TIME OF DAY
12. PERIODICALLY CHECK TREATED WATER FOR CHLORINE

DIME WATER, INC.

MAXI CURE WITH CLACK VALVE 1", 1.25"  
FOR COMPLETE VALVE MANUAL SEE <http://www.clackcorp.com/techsupport/downloads.html>